

Attachment 04-7-1-a-5

**Nisbet, Leona**

---

**From:** Leopold, Howard [Hleopold@cooperwiringdevices.com]  
**Sent:** Tuesday, June 15, 2004 11:05 AM  
**To:** 'cgrant@nfpa.org'  
**Cc:** 'lnisbet@nfpa.org'  
**Subject:** Appeal on Comment 2-91

Gentlemen:

Please accept the following revision of my email of yesterday. I had neglected to provide a rationale:

Please accept this appeal against the floor action seeking to overturn the Code Making Panel 2 decision to reject Comment 2-91. Relief requested is to maintain rejection of 2-91. My rationale is that a requirement for AFCI's on ALL branch circuits would cause the occurrence of vast issues of false tripping.

Thank you,

Howard Leopold  
Director, Electronic Engineering  
Cooper Wiring Devices/Eagle Electric/Arrow Hart  
718 361-4951  
718 361-5041 (fax)  
hleopold@cooperwiringdevices.com

-----Original Message-----

**From:** Leopold, Howard  
**Sent:** Monday, June 14, 2004 4:57 PM  
**To:** 'cgrant@nfpa.org'  
**Cc:** 'lnisbet@nfpa.org'  
**Subject:** Appeal on proposal 2-91

Please accept this appeal against the floor action seeking to overturn the Code Making Panel 2 decision to reject proposal 2-91. Relief requested is to maintain rejection of 2-91.

Thank you,

Howard Leopold  
Director, Electronic Engineering  
Cooper Wiring Devices/Eagle Electric/Arrow Hart  
45-31 Court Sq  
Long Island City, N.Y. 11101  
718 361-4951  
718 361-5041 (fax)  
hleopold@cooperwiringdevices.com