



Canadian Standards Association
Mississauga, Ontario
To the Part I Committee

Subject No. 2655 Chair: W.G. McMullan/S. Douglas Date: December 8, 2004

Title: Request for an Amendment to Rule 76-004(4)

Submitted by: DH Dunsire of Manitoba Hydro on October 25, 1995.

Proposal: Rule 76-004(4) – reword to read after “aerially” “..... supported on poles or other equally substantial means with the spacing.....”

Reasons for Request: In accordance with the requirements of Clause 3.4 of Appendix 'C' of the CEC Part I under legal amendments, the RAC Committee has reviewed the Code to seek to delete the use of the term 'acceptable' wherever practical as this is a subjective term and is dependant on an inspector decision.

In some cases the use of the term is not subjective and may be left alone.

Supporting Information: Good definitive terms without using the question word. Very acceptable.

Chair’s Comments: I agree with the proposal

Round One Subcommittee Deliberation:

All responding member agreed with the original proposal.

Subcommittee Recommendation:

Amend Rule 76-004 (4) as originally submitted.