



Canadian Standards Association
Mississauga, Ontario
To the Part I Committee

Subject No. 2760

Chair: M. Anderson

Date: December 8, 2004

Title: Transfer of Fire Pump Requirements, Rule 32-200

Submitted by: A. Kunert of TornaTech Inc., 401 Rue Deslauriers, Montreal, PQ, H4N 1W2,
Tel: (514) 334-0523, Fax: (514) 334-5448 on January 31, 1997.

Proposal: Amend Rule 32-200 (see attached)

Reasons for Request: NFPA 20 has eliminated the installation requirements for electrically driven fire pumps and published this requirement in the NEC NFPA 70

Chair's Comments: I agree with this proposal. Since this will involve a complete re-write of Section 32-200 through 21-212, care should be taken to ensure that the present requirements are captured in the new proposal.

Subcommittee Deliberation: The subject brought in the exact wording from the electrical items of NFPA 20 (now located in the NEC), the impacts would basically look at rewriting the whole section. Initially the subject received a lot of negatives for the reason that it was too big to digest. Since then there have been a few proposals to rewrite areas of this section that were of concern. We put the subject on hold for the last few years with the consent of the submitter to see if the changes met his request. The submitter has since retired and his replacement has consented to close the subject.

Chair's Recommendation: I would like to close the subject.