



Canadian Standards Association  
Mississauga, Ontario  
**To the Part I Committee**

---

Subject No. 3098

Chair: R. Chauhan

Date: October 18, 2004

---

Title: Height of Receptacles, Rule 70-122(2)

---

**Submitted by:** R. Leduc of Alberta Municipal Affairs, 16<sup>th</sup> floor, Commerce Place, Edmonton, Alberta, T5J 4L4, Tel: (780) 415-0481, Fax: (780) 427-8686 on November 22, 2002.

**Proposal:** Delete Rule 70-122(2)

**Reasons for Request:** Installations of residential occupancies have no height restrictions in applying the Rule 26-712(d). We can think of no rationale for imposing height restrictions in installations of relocatable structures when applying the same Rule [26-712(d)]. What purpose is served in a mobile home that is different than a residence or dwelling unit?

**Supporting Information:** Article 550.13 of the NEC deals with receptacle outlets in mobile homes. Height restrictions are not imposed for receptacles.

**Chair's Comments:** I agree with the proposal and support it. This will make the requirements consistent for dwelling units and for factory built relocatable structures.

**Subcommittee Deliberation:** All three of the five members who responded agreed with the proposal.

**Subcommittee Recommendation:** To accept the proposal as written.