

Approval of Electrical Equipment

Rule 2-024 (page 15)

The Ontario Electrical Safety Code recognizes certification organizations accredited by the Standards Council of Canada to approve electrical equipment. Only equipment bearing one of the marks or labels shown in the drawings is approved.

Equipment to meet the requirements of the Ontario Electrical Safety Code must be approved to Canadian standards. This is signified by the "C" outside the Entela, ETL, MET, OMNI, QAI, TUV Rheinland and UL marks. The "NRTL/C" shown with one Canadian Standards Association mark, and the "cULus" shown with one Underwriters Laboratories mark, indicate the equipment with those marks is also compliant with United States standards.




A Canadian Standards Association mark with "NRTL" only, and Underwriters Laboratories mark without the "c" at the eight o'clock position, indicates the equipment is compliant with United States standards.

**CERTIFICATION MARKS ACCEPTABLE UNDER
THE ELECTRICAL SAFETY CODE**

| | |
|---|--|
| Canadian Standards Association (CSA) |     |
| Entela |  |
| Intertek Testing Services |   |
| Met Laboratories Inc. (MET) |  |
| OMNI Environmental Services Inc. |  |
| Quality Auditing Institute |  |
| TUV Rheinland |  |
| Underwriters Laboratories Inc. (UL) |   |
| Underwriters' Laboratories of Canada (ULC) |  |

Field Evaluations may be done by Electrical Safety Authority or any accredited certification organization. Accepted field evaluation labels are shown below.

**FIELD EVALUATION MARKS ACCEPTABLE UNDER
THE ELECTRICAL SAFETY CODE**

| | | | |
|--|---|--|--|
| <p>CANADIAN STANDARDS ASSOCIATION (CSA)</p> |  | <p>INTERTEK TESTING SERVICES</p> |  |
| <p>ELECTRICAL SAFETY AUTHORITY (ESA)</p> |  | <p>ONTARIO HYDRO (OH)</p> |  |
| <p>ENTELE</p> |  | <p>UNDERWRITERS LABORATORIES OF CANADA (ULC)</p> |  |
| <p>INTERNATIONAL APPROVAL SERVICES (IAS)</p> |  | | |